



May 8, 2026

Transmitted Electronically

RE: Wellston  
Notice of Violation  
Related Correspondence  
Drinking Water Program  
Jackson County  
PWS ID OH4001912

Mayor Anthony Brenner  
City of Wellston  
203 E Broadway St  
Wellston OH 45692

**City of Wellston - Partial Resolution of Violation (PROV)**

Thank you for your responses to the sanitary survey notice of violation (NOV) letter dated April 7, 2026. A copy of the NOV is attached for your review.

**The following violations are outstanding. Please provide documentation of compliance, in writing, by the accepted dates listed below:**

<b>Outstanding Violations</b>		
<b>Violation:</b>	<b>Most recent response received from PWS:</b>	<b>Accepted schedule for resolution:</b>
Violation #1	April 29, 2026: The email from responsible operator David Gilliland stated that the excessive unaccounted-for water loss would be addressed by December 31, 2028.	<p><b>By December 31, 2028:</b></p> <ul style="list-style-type: none"> <li>Provide documentation that unaccounted-for water loss has been reduced to less than 30% of water produced by the treatment plants.</li> </ul>

Please be advised that violations cited above will continue until the violations have been properly resolved. Failure to comply with Chapter 6109 of the Ohio Revised Code and rules promulgated thereunder may result in an administrative or civil penalty of up to \$25,000 per day for each violation. It is imperative that you return to compliance. If circumstances delay

Southeast District Office  
2195 E. Front Street  
Logan, Ohio 43138 U.S.A.

740 | 385 8501  
epa.ohio.gov

the resolution of violations, you are requested to submit written correspondence of the steps that will be taken by the accepted schedule outlined above.

If you have any questions, please feel free to contact me by email at [eric.hart@epa.ohio.gov](mailto:eric.hart@epa.ohio.gov) or by phone at 740-380-5274.

Sincerely,



Eric Hart  
Environmental Specialist  
Division of Drinking and Ground Waters

EH/cd

Attachment: NOV

ec: Anthony Brenner, City of Wellston - [mayor@cityofwellston.org](mailto:mayor@cityofwellston.org)  
David Gilliland - [dgilliland@cityofwellston.org](mailto:dgilliland@cityofwellston.org)  
Jackson County Health Dept - [dramby@jchd.us](mailto:dramby@jchd.us)